

<u>Document No.</u>	<u>Title</u>	<u>Sponsor</u>	<u>Revision Summary</u>
Water/Wastewater/Reclaimed Details			
C-303 PG 1 of 2	FIRE HYDRANT	Warren White	Revision to delete Note #6 left on detail by error from 2015 removal.
C-303 PG 2 of 2	FIRE HYDRANT COLOR CODE	Karrie Mowrey	Revise color code numbers from 1, 2, 3 to Type 1, Type 2, Type 3. Matching historical referencing.
C-315	REDUCED PRESSURE-PRINCIPLE ASSEMBLY INSTALLATION 3", 4", 6", 8", 10"	Doug Toy	Revision to title "REDUCED PRESSURE-PRINCIPLE BACKFLOW PREVENTION - 4" AND LARGER". C-311 is intended for 3" and under assemblies.
C-404 PG 1 of 12	RECLAIMED WATER SERVICE CONNECTIONS	Robert Goff	Revision to service connection line size from 3" to 4" due to availability issues with 3" saddle connections.
C-404 PG 3 of 13	2" RECLAIMED WATER IRRIGATION SERVICE LINE INLINE PUMP TYPE	Robert Goff	Revision to service connection line size from 3" to 4" due to availability issues with 3" saddle connections.
Technical Design Manuals			
TDM #1&2	Water & Wastewater System Design	Warren White	Revision to valve spacing requirements on pg 14 adding spacing requirements for transmission mains at no greater than 1/2 mile.
TDM #1&2	Water & Wastewater System Design	John Knudson	Revisions to Chapter IV, Reclaimed Water Distribution System pertaining to spray irrigation restrictions, and private reclaimed system design considerations including available pressures and turnouts.
TDM #3	Drainage Policies and Standards	Karrie Mowrey	Revision on pg 11 inlet requirements since only allowing MAG 533 catch basin. Revision to pg 12 storm drain connections, clarifying allowances.
TDM #3	Drainage Policies and Standards	Karrie Mowrey / Jeff King	NEW section 6.11.5.4 stating requirements for recessed loading docks.
TDM #4	Street Design and Access Control	Warren White	Revisions to pg 18 and 32, adding ADA upgrade requirements to existing bus stops and designated on-street parking spaces.
TDM #5	Traffic Signal Design	Mike Mah	Revision to pg 4, Section 4 Signal Poles, referencing Figures TS-17A and TS-17B for Tenon locations and revision to typical pole placement requirements for ADA pushbutton access. Revisions to Figures TS-7, TS-12, TS-13 and TS17A. Deleting Figure TS-20, Sidewalk Extension Detail, in favor of revised Figure TS-13.
TDM #7	Traffic Barricade Design	Mike Mah	Revisions to pgs 4, 28 and 29 to clarify use of police officers at barricade locations, revisions pgs 15,18 and 19 to clarify taper length requirements and added Striping as a Channelization Device on pg 23. Also, other revisions including ADA requirements for pedestrian facilities and general housekeeping items including formatting and table of contents.