

Chandler Fire Department



Administrative headquarters:

151 E. Boston Street
Chandler, AZ 85225

Mailing address:

Mail Stop 801
P.O. Box 4008
Chandler, AZ 85244-4008

Contact us:

fire.prevention@chandleraz.gov

More information:

chandleraz.gov/fire
Twitter: @ChandlerFire
Facebook.com/ChandlerFire



Mayor Kevin Hartke & City Council

Chandler Fire Administration
Mail Stop 801
PO Box 4008
Chandler, AZ 85244-4008

*Official Document
Chandler Fire Department*

Chandler Fire Department



IS YOUR BUSINESS SAFE?

COMMERCIAL SELF-INSPECTION PROGRAM

DO NOT DISCARD

Is your business safe

Is your business safe

Use the following checklist to

Address/Suite Numbers

- ☐ Address & suite numbers should be at least 4" high & with a contrasting background on front & back doors
- ☐ Suite numbers on front and rear doors

Construction Features

- ☐ Ceiling tiles in place
- ☐ No holes in walls/fire resistive construction

Electrical Equipment

- ☐ No extension cords being used as permanent wiring
- ☐ No multi-plug adapters being used (*power strips are acceptable*)
- ☐ Electrical panel boxes, receptacles, light switches have proper covers on and/or closed
- ☐ No storage blocking electrical panel box (36" clearance)

Exits, Fire Escapes & Fire Alarms

- ☐ Emergency lighting is operable (check monthly and keep a record)
- ☐ Exit signs illuminated
- ☐ No padlocks/bars on exit doors while occupied
- ☐ All exit aisles clear from obstructions
- ☐ All fire alarm systems/equipment clear from obstructions
- ☐ All pull stations not obstructed from view
- ☐ System has annual test by a permitted company

Fire Extinguishers and Extinguishing Systems

- ☐ Extinguisher mounted on wall
- ☐ Extinguisher has annual test by a permitted company
- ☐ Extinguisher not obstructed from view
- ☐ Maximum travel distance to a fire extinguisher is 75 feet.

Fire Lanes

- ☐ Fire lanes properly marked and maintained
- ☐ Fire lanes not obstructed

Housekeeping

- ☐ Laundry room free of lint
- ☐ Combustibles not stored in equipment room
- ☐ Combustibles not stored next to heating source (*i.e. water heater*)
- ☐ Housekeeping inside and outside of building is orderly
- ☐ No storage in exits
- ☐ No storage within 18" of sprinkler heads
- ☐ No storage within 24" of ceiling in unsprinklered areas

Restaurants/Assembly

- ☐ Occupancy load posted in the building

Sprinkler and Standpipe Systems

- ☐ Fire department caps/adapters are in place
- ☐ Fire department connections/standpipe are not blocked
- ☐ Sprinkler heads are not painted
- ☐ System has annual test by a permitted company
- ☐ Extra sprinkler head equipment in sprinkler cabinet

Storage and Handling of Flammable Liquids Gas

- ☐ Compressed gas cylinders must be secured
- ☐ Incompatible materials not stored together

Kitchens

- ☐ Have required K extinguisher for deep fryers
- ☐ Hood system is free of grease and clean
- ☐ Hood system has current 6 month inspection by permitted company

This is not an all-inclusive list.

Please contact Fire Prevention if your business information does not correspond with the front of this form or with any questions you may have at 480-782-2120 or fire.prevention@chandleraz.gov