

FIRE PREVENTION CHANGE SUMMARY 2020

**Document Title Revision Summary**

**Standard**

<p>FD102</p>	<p>FIRE LINE INSTALLATION (NO ON-SITE HYDRANTS REQUIRED/FOR SMALL SITES AND/OR SINGLE BUILDINGS)</p>	<p>UPDATED CITY OF CHANDLER LOGO AND ADDED FIRE DEPARTMENT LOGO.                  UPDATED SIGNATURE.                  DELETE POST INDICATOR VALVE DRAWING AND ACCOMPANING LANGUAGE.                  NOTES:                  REVISION OF #5 NOTES: FDC'S AND PIV'S SHALL BE PAINTED RED AND SIGNED PER FIRE DEPT. DETAIL NO. FD104 SIGNAGE.                  ADD NEW #6 NOTES: FIRE SPRINKLER RISER SHALL BE DESIGNED PER FIRE DEPT. DETAIL NO. FD105.</p>
<p>FD103</p>	<p>FIRE LINE INSTALLATION (ON-SITE HYDRANT REQUIRED/FOR LARGE SITES AND/OR MULTIPLE BUILDINGS)</p>	<p>UPDATED CITY OF CHANDLER LOGO AND ADDED FIRE DEPARTMENT LOGO.                  UPDATED SIGNATURE.                  DELETE POST INDICATOR VALVE DRAWING AND ACCOMPANING LANGUAGE.                  REVISION OF #5 NOTES: FIRE SPRINKLER (FS) SYSTEM RISER (FD105) SHALL BE SHOWN ON CIVIL AND FS BUILDING PLANS.PROVIDE A KEY BOX FOR FIRE DEPARTMENT ACCESS.</p>
<p>FD104</p>	<p>FIRE DEPARTMENT VALVE SIGNAGE</p>	<p>UPDATED CITY OF CHANDLER LOGO AND ADDED FIRE DEPARTMENT LOGO.                  UPDATED SIGNATURE.</p>
<p>FD105</p>	<p>FIRE SPRINKLER SYSTEM RISER COMMERCIAL INSTALLATION</p>	<p>UPDATED CITY OF CHANDLER LOGO AND ADDED FIRE DEPARTMENT LOGO.                  UPDATED SIGNATURE.                  ADD PRESSURE RELIEF VALVE ARROW AND VERBIAGE.                  REVISION OF RISER CONTROL VALVE LANGUAGE.</p>
<p>FD106</p>	<p>FIRE RISER ROOM AND FIRE ALARM PANEL SIGNAGE</p>	<p>UPDATED CITY OF CHANDLER LOGO AND ADDED FIRE DEPARTMENT LOGO.                  UPDATED SIGNATURE.                  REVISION OF SIGNAGE B LANGUAGE: FACP.</p>
<p>FD107</p>	<p>FIRE RISER ROOM AND FIRE ALARM PANEL SIGNAGE</p>	<p>UPDATED CITY OF CHANDLER LOGO AND ADDED FIRE DEPARTMENT LOGO.                  UPDATED SIGNATURE.                  DELETE SIGN EXAMPLE DRAWING.                  DELETE #4 NOTES.                  RENUMBER REMAINING NOTES #4 THROUGH #6.</p>

FIRE PREVENTION CHANGE SUMMARY 2020

**Document Title Revision Summary**

**Standard**

FD108	FIRE RISER ROOM AND FIRE ALARM PANEL SIGNAGE	UPDATED CITY OF CHANDLER LOGO AND ADDED FIRE DEPARTMENT LOGO. UPDATED SIGNATURE.
FD115	BLOCKED DOOR SIGNAGE	UPDATED CITY OF CHANDLER LOGO AND ADDED FIRE DEPARTMENT LOGO. UPDATED SIGNATURE.
FD141	FIRE APPARATUS ROADWAYS AND TURNAROUNDS	UPDATED CITY OF CHANDLER LOGO AND ADDED FIRE DEPARTMENT LOGO. UPDATED SIGNATURE.
FD143	FIRE RISER ROOM AND FIRE ALARM PANEL SIGNAGE	UPDATED CITY OF CHANDLER LOGO AND ADDED FIRE DEPARTMENT LOGO. UPDATED SIGNATURE.
FD144	FIRE SPRINKLER RISER W/BACKFLOW PREVENTION (DOWNTOWN INSTALLATION ONLY)	UPDATED CITY OF CHANDLER LOGO AND ADDED FIRE DEPARTMENT LOGO. UPDATED SIGNATURE. ADD PRESSURE RELIEF VALVE ARROW AND VERBIAGE.
FD151	ADDRESS IDENTIFICATION	UPDATED CITY OF CHANDLER LOGO AND ADDED FIRE DEPARTMENT LOGO. UPDATED SIGNATURE. REVISION TO GENERAL INFORMATION: Minimum: 0-50' = 4" 50-200' = 12" 201-300' = 14" 301-400' = 16"